

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

File Number:	SOP1-239572-01-5100
Test Date:	2017-04-26
Publication Date:	2017-08-21
Revision Date:	N/A
Reappraisal Date:	2020-08-21



COLVENT 830 MEMBRANE SYSTEM WITH VAPOR BARRIER OVER MECHANICALLY FASTENED THERMAL BARRIER

(PARS) PARTIALLY ATTACHED (HYBRIDE) ROOFING SYSTEM

Roofing System Summary

Cap sheet membrane:	Modified bitumen membrane / Torch applied
Base sheet membrane:	Modified bitumen membrane / Semi-adhered (self-adhering strips)
Cover board:	N/A
Insulation (top):	Polyisocyanurate foam insulation board 1220 x 1220 x 38 mm (4' x 4' x 1½") / Adhered
Insulation (bottom):	Polyisocyanurate foam insulation board 1220 x 1220 x 38 mm (4' x 4' x 1½") / Adhered
Vapour barrier:	Modified bitumen membrane / Torch applied
Thermal barrier:	Moisture and fire resistant gypsum board 1220 x 2440 x 12,7 mm (4' x 8' x ½") / Mechanically fastened
Decking:	Steel deck

Dynamic Uplift Resistance (DUR) as per CSA A123.21

System Designation	Measured Value	Computed Value (To Include 1.5 Experimental Factor)
A	-6,0 kPa (-125 psf)	-4,0 kPa (-83 psf)

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-239572-01-5100

Products

CAP SHEET MEMBRANE				
TESTED PRODUCT: Membrane composed of SBS modified bitumen and a composite reinforcement				
System	Application Method			
A	Torch applied			
ELIGIBLE PRODUCT(S)				
Soprema	Colvent Traffic Cap 860			

BASE SHEET MEMBRANE			
TESTED PRODUCT: Membrane composed of SBS modified bitumen and reinforced with a glass mat			
System	Application Method	Row spacing	Fasteners spacing
A	Self-adhered (discontinuous self-adhesive strips)	N/A	N/A
ELIGIBLE PRODUCT(S)			
Soprema	Colvent Base 830		

COVER BOARD
TESTED PRODUCT: N/A



INSULATION (Top Row)				
TESTED PRODUCT: Polyisocyanurate foam insulation board laminated on both sides with polymer-coated glass fibers facers				
System	Application Method	Fastening Rate		
A	Adhered with Duotack	Ribbons at 305 mm (12 in) o.c.		
ELIGIBLE THICKNESS(ES)				
38 to 102 mm (1½ to 4 in)				
FASTENING METHOD				
Duotack adhesive				
FASTENING PATTERN				
<p>System A</p>				
ELIGIBLE PRODUCT(S)				
Soprema	Sopra-ISO Plus			



INSULATION (Bottom Row)				
TESTED PRODUCT: Polyisocyanurate foam insulation board laminated on both sides with fiber reinforced organic felt				
System	Application Method	Fastening Rate		
A	Adhered with Duotack	Ribbons at 305 mm (12 in) o.c.		
ELIGIBLE THICKNESS(ES)				
38 to 102 mm (1½ to 4 in)				
FASTENING METHOD				
Duotack adhesive				
FASTENING PATTERN				
<p>System A</p>				
ELIGIBLE PRODUCT(S)				
Soprema	Sopra-ISO			

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-239572-01-5100

VAPOUR BARRIER			
TESTED PRODUCT: Membrane composed of a glass mat reinforcement and SBS modified bitumen			
System	Fastening Method		Primer
A	Torch applied		Elastocol 500
ELIGIBLE PRODUCT(S)			
Soprema	Elastophene SP 2.2		

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-239572-01-5100

THERMAL BARRIER				
TESTED PRODUCT: Moisture and fire resistant gypsum board, covered with non-combustible fiberglass felt and non-asphaltic coating				
System	Application Method		Fastening Rate	
A	Mechanically fastened		16 fasteners / board 1220 x 2440 mm (4' x 8')	
ELIGIBLE THICKNESS(ES)				
12,7 mm (1/2 in) minimum				
FASTENING METHOD				
Screws and plates				
FASTENING PATTERN(S)				
<p>System A</p>				
ELIGIBLE PRODUCT(S)				
Georgia-Pacific	DensDeck Prime			

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-239572-01-5100

FASTENERS		
TESTED PRODUCT(S): #12 roofing fasteners		
System	Screws	Plates
A	#12 DF x 41 mm (1 5/8 in)	Round metal of 76 mm (3 in)
FASTENERS MEASURED PULL OUT RESISTANCE		
178 kgf (392 lbf)		
ELIGIBLE PRODUCT(S)		
Dekfast	#12 Dekfast x 41 mm (1 5/8 in)	Dekfast round metal plates

ADHESIVE			
TESTED PRODUCT: Low-rise, two-component, polyurethane adhesive			
System	Ribbon's spacing	Primer	
A	305 mm (12 in) o.c.	N/A	
ELIGIBLE PRODUCT(S)			
Soprema	Duotack		

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-239572-01-5100

General Notes

1. Decking:

The tests performed by **exp** services inc. («**exp**») were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi).

Equivalency; tests have demonstrated that the heat welded vapour barrier in the system herein described is suitable for application on concrete deck properly primed with Elastocol 500.

Tests could be conducted on 4 'x 8' x 5/8 "standard plywood deck to assess eligibility for possible equivalencies.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

2. Deck equivalency products:

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

3. Fasteners Pull Out Resistance:

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

4. Adhesive Pull Resistance:

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

5. Note on adhesive:

Follow all guide lines or supplementary instructions from the manufacturer regarding adhesive application.

6. Equivalent products:

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on **exp** application form, to be studied for approval.

7. Optional components:

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

8. Experimental factor:

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed experimental factor of 1,5.

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-239572-01-5100

9. Building Wind Load Calculation:

An online calculator is available at <http://www.exp.com/fr/rooftesting>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without experimental factor. It will also compute perimeter's and corner's zone dimensions.

10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from **exp**.

11. Notice :

Exp reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

12. Version tracking table:

2017-08-21	First edition

Prepared by:

exp Services Inc.

August 21st 2017

Date

Serge Rochon, P.Eng.
Provincial Director – Roofing & Building Envelope
OIQ N° 114865