

## Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

File Number:	SOPI-DRS-00231265-12-5100
Test Date:	2016-09-26
Publication Date:	2016-12-21
Reappraisal Date:	2019-12-21



### SOPRASMART ISO HD 180 ISO ADHERED WITH DUOTACK (AARS) ADHESIVE APPLIED ROOFING SYSTEM

#### Roofing System Summary

Cap sheet membrane:	Modified bitumen membrane / Torch applied
Base sheet membrane:	N/A
Cover board:	N/A
Insulation:	Board composed of a bitumen membrane laminated over two polyisocyanurate boards 914 x 2440 x 6 mm (3 ft x 8 ft x 2 9/16 in) / Adhered
Vapor barrier:	Self-adhering membrane
Thermal barrier:	N/A
Decking:	Steel deck

#### Dynamic Uplift Resistance (DUR) as per CSA A123.21

System Designation	Measured Value	Computed Value (To Include 1.5 Safety Factor)
A	-3,6 kPa (-75 psf)	-2,4 kPa (-50 psf)

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP1-DRS-00231265-12-5100

### Products

CAP SHEET MEMBRANE				
TESTED PRODUCT : Membrane is composed of a non-woven polyester reinforcement and SBS modified bitumen				
System	Application Method			
A	Torch applied			
ELIGIBLE PRODUCT(S)				
Soprema	Sopralene Flam 250 GR			

BASE SHEET MEMBRANE				
TESTED PRODUCT : N/A				

COVER BOARD				
TESTED PRODUCT : N/A				



INSULATION (Top Row)				
<b>TESTED PRODUCT :</b> Support board composed of a SBS modified bitumen membrane with a non-woven polyester reinforcement, laminated to a rigid ½ inch high density polyisocyanurate board laminated over a rigid polyisocyanurate 1½ inch board				
System	Application Method		Fastening Rate	
<b>A</b>	Adhered		Ribbons at 305 mm (12 in)	
ELIGIBLE THICKNESS(ES)				
51 mm (2 in)				
FASTENING METHOD				
Duotack adhesive				
FASTENING PATTERN				
<p>Système A</p>				
ELIGIBLE PRODUCT(S)				
<b>Soprema</b>	Soprasmart ISO HD 180 ISO 65 mm (2 9/16 in)			



INSULATION (Bottom Row)	
TESTED PRODUCT : N/A	

FASTENERS PULL OUT RESISTANCE	
TESTED PRODUCT(S) : N/A	

ADHESIVE			
TESTED PRODUCT : Low-rise, two-component, polyurethane adhesive			
System	Ribbon's spacing		Primer
A	305 mm (12 in.)		N/A
ELIGIBLE PRODUCT(S)			
Soprema	Duotack		

VAPOR BARRIER			
TESTED PRODUCT : Self-adhesive membrane composed of a trilaminated woven polyethylene and SBS modified bitumen			
System	Fastening Method		Primer
A	Self-adhered		N/A
ELIGIBLE PRODUCT(S)			
Soprema	Sopravap'R		
ELIGIBLE PRODUCT(S) over thermal barrier : N/A			

THERMAL BARRIER	
TESTED PRODUCT : N/A	

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP-DRS-00231265-12-5100

### General Notes

#### 1. Decking:

Tests were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi). The tests could also be performed on concrete deck or standard 4' x 8' x 5/8" plywood deck.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

#### 2. Deck equivalency products:

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

#### 3. Fasteners Pull Out Resistance:

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

#### 4. Adhesive Pull Resistance:

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

#### 5. Note on adhesive:

Follow all guide lines or supplementary instructions from the manufacturer regarding adhesive application.

#### 6. Equivalent products:

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on **exp** application form, to be studied for approval.

#### 7. Optional components:

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

#### 8. Safety factor:

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed safety factor of 1,5.

#### 9. Building Wind Load Calculation:

An online calculator is available at <http://www.exp.com/fr/rooftesting>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without safety factor. It will also compute perimeter's and corner's zone dimensions.

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP1-DRS-00231265-12-5100

### 10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from **exp**.

### 11. Notice :

**Exp** reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

### 12. Change(s) included in review(s) :

2016-12-21	First edition

Prepared by:

**exp** Services Inc.

---

Serge Rochon, P.Eng.  
Provincial Director – Roofing & Building Envelope  
OIQ N° 114865

---

January 26<sup>th</sup>, 2017

Date