

# Roof System Assessment Report of Wind Uplift Resistance

**LLS Document Number:** PUB-DRU237226 **Publication date:** February 08, 2013

**Revised:** 

**Revaluation :** February 08, 2016

Page 1 of 3

## Manufacturer:

# CARLISLE SYNTEC

Authorized membrane production sites: Mountain Top, PA; Greenville, IL; Hillside, NJ - USA

# Roofing System Summary: PVC RhinoBond System

Membrane: Sure-Flex PVC or equivalent membrane
Insulation: Polyiso HP-H or equivalent product
Vapour barrier: 725 TR or equivalent product

- Thermal barrier: Optional

- Decking: Steel deck 22 gauge or equivalent

- Dynamic Uplift Resistance (DUR) as per CSA A123.21 standard: -3.4 kPa (-70 psf)

# - Notes: **Equivalent products:**

Only equivalent products included into the roofing system's report are admissible.

# **Optional components:**

Components of the roofing system designated as optional may be included or excluded from the roofing system which will not change the published dynamic uplift resistance (DUR).

#### **Safety factor:**

As required by in the CSA A123.21 standard, the published dynamic uplift resistance (DUR) are reduced by a safety factor of 1.5.

## Admissible wind uplift load calculation:

An online calculator is available at <u>www.sigders.ca</u>. The user will have to provide the following information:

- building location,
- building geometry,
- building exposure,
- building openings,
- building importance factor.

The calculator will display the allowable design load of the roof's field surface, edges and corners as well as the dimensions of the edge and corner zones.

# **Technical Advisories:**

Assessment reports must be read in conjunction with technical advisories issued by Les Services **exp** inc.

#### Values

For this document, the metric values are the standard and values in parentheses are for information only.

#### Notice

Les Service **exp** inc. reserve their right to withdraw, without prior notice, the test report performed as per CSA A123.21 standard.



# Roof System Assessment Report of Wind Uplift Resistance

**LLS Document Number:** PUB-DRU237226 **Publication date:** February 08, 2013

Revised:

**Revaluation :** February 08, 2016

Page 2 of 3

## **Roofing System's Specific Data:**

**Membrane:** 

- Membrane: Sure-Flex PVC 1.3 mm (50 mil)

- Membrane description: White or colored PVC roofing membrane

- Equivalents: 1.5 or 2.1 mm (60 or 80 mil.) Sure-Flex; 1.3, 1.5 or 2.1 mm (50, 60 or 80 mil.) Sure-

Flex PVC KEE

- Attachment method: | Spacing: | Dynamique Uplift Resistance (DUR):

Max. Row Fasteners Observed on test With 1.5 Safety factor 610 mm (24 in.) 610 mm (24 in.) -5.02 kPa (-105 psf) -3.4 kPa (-70 psf)

# **Coverboard (optional):**

- Type: Carlisle HP Recovery Board

- Supplier: Carlisle SynTec

- Description: Rigid overlayment board

- Equivalents: DensDeck, DensDeck Prime, Securock, oriented strand board (OSB), plywood,

gypsum, Carlisle SecurShield HD or HD Plus and Hunter Panels H-Shield HD or

HD90

- Thickness: minimum 6 mm (1/4 inch)

- Attachment method: Fasteners and plates (see insulation section)

Note: When a coverboard is used, fasteners and plates normally used to attach the insulation are used to simultaneously attach the coverboard and insulation (see insulation section below).

# **Insulation:**

- Insulation type: Polyiso HP-H (or approved equivalent)

- Supplier: Carlisle Syntec

- Insulation description: Polyisocyanurate foamed plastic between two facers with a compressive strength of

138 kPa (20 psi) in accordance with the ASTM D 1621 standard.

- Attachment method: 1 fastener and plate per 0.372 m<sup>2</sup> (4ft<sup>2</sup>)

- Equivalents: EPS composite Board, Carlisle SecurShield or Securshield HD Composite, Hunter

Panels H-Shield, Hunter Panels H-Shield-CG, H-Shield HD Composite

- Fastener type: HP-X fasteners (no. 15)

- Plate type: Carlisle RhinoBond plates, 75 mm (3 in.) round.

# **Vapour Barrier:**

- Vapour barrier: Carlisle CCW 725 TR- Supplier: Carlisle Syntec

Attachment method: Self-adhered or loosely laid and sealed at the laps in the case of polyethylene
Equivalents: Carlisle CCW 725, CCW 705 or minimum 0.15 mm (6 mil) thick polyethylene

# **Thermal Barrier (optional):**

- Type: Gypsum panel- Supplier: Generic



# Roof System Assessment Report of Wind Uplift Resistance

**LLS Document Number:** PUB-DRU237226 **Publication date:** February 08, 2013

**Publication date:** Revised:

**Revaluation:** February 08, 2016

Page 3 of 3

- Description: Panel with gypsum core - Thickness: 6 mm (1/4 in.) minimum

- Attachment method: Loosely laid, adhesively attached or mechanically attached

- Equivalents: DensDeck, DensDeck Prime, Securock

**Decking:** 

- Supplier: Generic

- Decking type: Galvanized or aluminum/zinc alloy coated steel in accordance with ASTM A653,

ASTM A792, ASTM A1008 or CSSBI 10M standards.

- Thickness: 0.76 mm (0.03 in.) minimum, with a yield strength of 230 MPa (33 ksi) and a tensile

strength of 310 MPa (45 ksi) commonly defined as being of a 22 gauge minimum

thickness.

- Equivalents: Any decking material with pull-out resistance equal to or greater than the referenced

below.

- Attachment method: The deck's fastening to the supporting structure must be strong enough to resist wind

uplift loads (adjusted as per NBC requirements).

- Fastening uplift resistance

(CSA S136.F04): 2.0 kN (450 pf)